Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 12:21 pm

PWS ID: UTAH18039 Name: FOREST GLEN B AND C WATER SYSTEM

Legal Contact FOREST GLEN B&C WATER SYS Rating: Approved

MARK BARTON Rating Date: 06/03/2008

Address: 1849 E SOMERVILLE DR Activity Status: Active

SANDY, UT 84093

Phone Number: 801-572-4321

City Served (Area):

County: SALT LAKE COUNTY

Gal/Day Gal/Min

System Type: Non-community

Last Inv Update: 05/26/2010

Activity Status Cd: Active

Last Snty Srv Dt: 06/30/2008

Total Dsgn Cap:

Surveyor: RANDY S WILLIAMS

Total Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact			Phone Numbers							
Type	Name	Title	Office	Emergency	Email Address					
AC	BARTON, MARK		801-572-4321							

Service Connections

Connection			Number	
Type	Meter Type Code	Meter Size	Connections	
Residential	Unknown	0	44	
			44 Tota	al Svc Connections

Storage

Total Storage: 50,378 GAL Number of Units: 2 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	47,878 GAL	Concrete		Α	
ST002	STORAGE FACILITY ST002	Ground	2,500 GAL	Concrete		Α	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Status	Process
TP001	B AND C CHLORINATION		A	

Distribution System

Pump Type	Total Dyn I	Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	LITTLE DOLLY SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	UTAH18044 FOREST GLEN	Active	CC				No	GW	Permanent	1/1 to 12/31	

^{*}Reports measured flow for wells, approved design capacity for all other sources.